

JEFFERSON STATE PRESCHOOL

10203 FIRMONA AVENUE
LENNOX, CA

1 Inspection Visit Since 2023 · 1 Finding

Most recent inspection: May 9, 2023

1 Important

Across 1 inspection since 2023, the issues cited most often were To LPA Water Outlet in Room 24 Is Not Available to Children. Classroom Is Closed. 8 9 10 11 12 13 14 Based on Observation and Review of Lead Water Testing Samples Taken on 3/23, Revealed That Levels of Lead Were Beyond Allowable Amount Deemed by the State of California. Room 23 Water Outlet Had a Lead Exceedance Levels of Sample "D" at 7.3. This Poses a Potential Health and Safety Risk to Children in Care. 8 9 10 11 12 13 14 Facility Will Make Repairs, Notified Famiiles of the Lead Testing and Will Provide LPA with a Copy of the Notificaiton by 5/28/23. A Restest Will Been Completed and Once Results Are Availalbe, a Copy Will Be Sent Out to LPA. 1 2 3 4 5 6 7 1 2 3 4 5 6 7 1 2 3 4 5 6 7 Failure to Correct the Cited Deficiency(ies), on or Before the Plan of Correction (POC) Due Date, May Result in a Civil Penalty Assessment. (1). The single finding was not critical.

Inspection Visits

May 9, 2023 1 Finding 1 Important

- To LPA Water Outlet in Room 24 Is Not Available to Children. Classroom Is Closed. 8 9 10 11 12 13 14 Based on Observation and Review of Lead Water Testing Samples Taken on 3/23, Revealed That Levels of Lead Were Beyond Allowable Amount Deemed by the State of California. Room 23 Water Outlet Had a Lead Exceedance Levels of Sample "D" at 7.3. This Poses a Potential Health and Safety Risk to Children in Care. 8 9 10 11 12 13 14 Facility Will Make Repairs, Notified Famiiles of the Lead Testing and Will Provide LPA with a Copy of the Notificaiton by 5/28/23. A Restest Will Been Completed and Once Results Are Availalbe, a Copy Will Be Sent Out to LPA. 1 2 3 4 5 6 7 1 2 3 4 5 6 7 1 2 3 4 5 6 7 Failure to Correct the Cited Deficiency(ies), on or Before the Plan of Correction (POC) Due Date, May Result in a Civil Penalty Assessment.

CCR 101700.3(b)(1) 1 2 3 4 5 6 7 101700.3(b)(1),California Lead Action Level at Child Care Centers. A result with values of 5.5 ppb or greater shall be deemed an Action Level...

About this report

Childery generates this report from public inspection records published by the California Department of Social Services, Community Care Licensing Division. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the California Department of Social Services, Community Care Licensing Division.