

## HACIENDA CHILD DEVELOPMENT CENTER

4671 CHABOT DRIVE  
PLEASANTON, CA

### 1 Inspection Visit Since 2023 · 1 Finding

Most recent inspection: Feb 10, 2023

#### 1 Important

Across 1 inspection since 2023, the issues cited most often were Is Already in Placed, Two Facuets Are Covered with "Do Not Use" Sign Posted. The Parents Supplies Water Bottles and Facility Refills as Needed. New Faucets Are Ordered to Replace the Existing Ones. Due to Low Enrollment 2 of the Classrooms Are Not in Use. (Room 6 & 2) 8 9 10 11 12 13 14 This Requirement Was Not Met as Evidenced By: Based on Lead Testing Results. Based on Lead Testing Results, 4 (Four) Faucets Tested Have Lead Levels Exceeding 5.5ppb Which Poses a Potential Health and Safety Risk to Children in Care. 8 9 10 11 12 13 14 Director Must Submit Proof to LPA via Email the Results Once the Facucets Pass Testing. The Documentation Must Be Submitted to LPA No Later Than 03/10/2023. Email: Lorraine.Dacanay-Breaux@dss.ca.gov 1 2 3 4 5 6 7 1 2 3 4 5 6 7 1 2 3 4 5 6 7 Failure to Correct the Cited Deficiency(ies), on or Before the Plan of Correction (POC) Due Date, May Result in a Civil Penalty Assessment. (1). The single finding was not critical.

### Inspection Visits

Feb 10, 2023 1 Finding 1 Important

- Is Already in Placed, Two Facuets Are Covered with "Do Not Use" Sign Posted. The Parents Supplies Water Bottles and Facility Refills as Needed. New Faucets Are Ordered to Replace the Existing Ones. Due to Low Enrollment 2 of the Classrooms Are Not in Use. (Room 6 & 2) 8 9 10 11 12 13 14 This Requirement Was Not Met as Evidenced By: Based on Lead Testing Results. Based on Lead Testing Results, 4 (Four) Faucets Tested Have Lead Levels Exceeding 5.5ppb Which Poses a Potential Health and Safety Risk to Children in Care. 8 9 10 11 12 13 14 Director Must Submit Proof to LPA via Email the Results Once the Facucets Pass Testing. The Documentation Must Be Submitted to LPA No Later Than 03/10/2023. Email: Lorraine.Dacanay-Breaux@dss.ca.gov 1 2 3 4 5 6 7 1 2 3 4 5 6 7 1 2 3 4 5 6 7 Failure to Correct the Cited Deficiency(ies), on or Before the Plan of Correction (POC) Due Date, May Result in a Civil Penalty Assessment.

CCR 101238(a) 1 2 3 4 5 6 7 101238 Buildings and Grounds (a) The child care center shall be clean, safe, sanitary and in good repair at all times to ensure the safety and...

#### About this report

Childery generates this report from public inspection records published by the California Department of Social Services, Community Care Licensing Division. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the California Department of Social Services, Community Care Licensing Division.