

SKYLINE COLLEGE CDC (INFANT)

3300 COLLEGE DRIVE
SAN BRUNO, CA

1 Inspection Visit Since 2024 · 1 Finding

Most recent inspection: Oct 1, 2024

● 1 Important

Across 1 inspection since 2024, the issues cited most often were Based on Observation and Record Review, the Licensee Did Not Comply with the Section Cited Above by Having Lead Water Test Results Over the Exeedence Level of 5.5ppb, Which Poses a Potential Health, Safety or Personal Rights Risk to Persons in Care. POC Due Date: 11/01/2024 (1). The single finding was not critical.

Inspection Visits

Oct 1, 2024 1 Finding ● 1 Important

- **Based on Observation and Record Review, the Licensee Did Not Comply with the Section Cited Above by Having Lead Water Test Results Over the Exeedence Level of 5.5ppb, Which Poses a Potential Health, Safety or Personal Rights Risk to Persons in Care. POC Due Date: 11/01/2024**

WD 101700(b) Written Directives for Lead Testing (b) All licensed Child Care Centers operating in buildings constructed before January 1, 2010, shall test their water for lead...

About this report

Childery generates this report from public inspection records published by the California Department of Social Services, Community Care Licensing Division. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the California Department of Social Services, Community Care Licensing Division.