

SCHOLARSHINE MONTESSORI

8196 MULBERRY AVENUE
FONTANA, CA

1 Inspection Visit Since 2024 · 1 Finding

Most recent inspection: Oct 30, 2024

● 1 Important

Across 1 inspection since 2024, the issues cited most often were Based on Observation, There Was No Carbon Monoxide in the Facility. Both, Director and Owner Stated That the Carbon Monoxide Must Have Been Taken Down During the Renovation of the Kitchen and Not Put Back On. The Owner Stated It Must Have Been One Month Since the Kitchen Has Been Remodeled. Owner Stated That She's Been Telling Them to Put It Back On. This Poses an Immediate Health, Safety or Personal Rights Risk to Persons in Care. POC Due Date: 10/31/2024 (1). The single finding was not critical.

Inspection Visits

Oct 30, 2024 1 Finding ● 1 Important

- **Based on Observation, There Was No Carbon Monoxide in the Facility. Both, Director and Owner Stated That the Carbon Monoxide Must Have Been Taken Down During the Renovation of the Kitchen and Not Put Back On. The Owner Stated It Must Have Been One Month Since the Kitchen Has Been Remodeled. Owner Stated That She's Been Telling Them to Put It Back On. This Poses an Immediate Health, Safety or Personal Rights Risk to Persons in Care. POC Due Date: 10/31/2024**

HSC 1596.954 Licensure Requirements Every licensed child day care center shall have one or more carbon monoxide detectors in the facility that meet the standards established in...

About this report

Childery generates this report from public inspection records published by the California Department of Social Services, Community Care Licensing Division. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the California Department of Social Services, Community Care Licensing Division.