

CLASSIC ED LEARNING CENTER

301 ISABEL STREET
GLENDALE, CA

1 Inspection Visit Since 2024 · 1 Finding

Most recent inspection: Mar 8, 2024

1 Important

Across 1 inspection since 2024, the issues cited most often were Due Date. 8 9 10 11 12 13 14 Based on Water Testing Results That Was Completed on 10/06/23, Sample Site D, Kitchen Faucet Identified with Action Level Exceedance of 5.5 Ppb as Identified in WD Section 101700.3 Are Not Deemed Safe for Drink. This Poses a Potential Health and Safety Risk to Children in Care. 8 9 10 11 12 13 14 1 2 3 4 5 6 7 1 2 3 4 5 6 7 1 2 3 4 5 6 7 Failure to Correct the Cited Deficiency(ies), on or Before the Plan of Correction (POC) Due Date, May Result in a Civil Penalty Assessment. (1). The single finding was not critical.

Inspection Visits

Mar 8, 2024 1 Finding 1 Important

- **Due Date. 8 9 10 11 12 13 14 Based on Water Testing Results That Was Completed on 10/06/23, Sample Site D, Kitchen Faucet Identified with Action Level Exceedance of 5.5 Ppb as Identified in WD Section 101700.3 Are Not Deemed Safe for Drink. This Poses a Potential Health and Safety Risk to Children in Care. 8 9 10 11 12 13 14 1 2 3 4 5 6 7 1 2 3 4 5 6 7 1 2 3 4 5 6 7 Failure to Correct the Cited Deficiency(ies), on or Before the Plan of Correction (POC) Due Date, May Result in a Civil Penalty Assessment.**

CCR 101700.3(b)(1) 1 2 3 4 5 6 7 101700.3(b)(1) California Lead Action Level at Child Care Centers. (b) Testing results with fractional readings of parts per billion (ppb) 0.5 ppb...

About this report

Childery generates this report from public inspection records published by the California Department of Social Services, Community Care Licensing Division. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the California Department of Social Services, Community Care Licensing Division.