

KREATIVE KIDS LEARNING CENTER

7020 WYNDHAM DR
SACRAMENTO, CA

1 Inspection Visit Since 2022 · 1 Finding

Most recent inspection: Sep 15, 2022

● 1 Important

Across 1 inspection since 2022, the issues cited most often were Based on Results of a Test Conduct on a Faucet on July 07, 2022 Indicated 10 Ppb in the Faucet Water, Which Exceed 5.5 Ppb Requirement. This Is a Potential Risk to the Health and Safety of Children in Care if Not Corrected. POC Due Date: 10/31/2022 (1). The single finding was not critical.

Inspection Visits

Sep 15, 2022 1 Finding ● 1 Important

- **Based on Results of a Test Conduct on a Faucet on July 07, 2022 Indicated 10 Ppb in the Faucet Water, Which Exceed 5.5 Ppb Requirement. This Is a Potential Risk to the Health and Safety of Children in Care if Not Corrected. POC Due Date: 10/31/2022**

WD 101700.3(b)(1) California Lead Action Level at Child Care Centers. b) Testing results with fractional ppb readings of 0.5 or greater shall be rounded up to the nearest whole...

About this report

Childery generates this report from public inspection records published by the California Department of Social Services, Community Care Licensing Division. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the California Department of Social Services, Community Care Licensing Division.