

KINGS CHRISTIAN SCHOOL, INC.

900 EAST D STREET
LEMOORE, CA

1 Inspection Visit Since 2025 · 1 Finding

Most recent inspection: Jan 22, 2025

● 1 Important

Across 1 inspection since 2025, the issues cited most often were Based on Record Review Authored by Dellavalle Laboratory Inc.,a Result of (ALE) of 14 and 5.6 Ppb for Two Outlets Which Are Out of Compliance Over the Allowable ALE 5.5ppb. This Poses a Potential Health, Safety or Personal Rights Risk to Persons in Care. POC Due Date: 01/31/2025 (1). The single finding was not critical.

Inspection Visits

Jan 22, 2025 1 Finding ● 1 Important

- **Based on Record Review Authored by Dellavalle Laboratory Inc.,a Result of (ALE) of 14 and 5.6 Ppb for Two Outlets Which Are Out of Compliance Over the Allowable ALE 5.5ppb. This Poses a Potential Health, Safety or Personal Rights Risk to Persons in Care. POC Due Date: 01/31/2025**

WD 101700.3 This requirement is not met as evidenced by:

About this report

Childery generates this report from public inspection records published by the California Department of Social Services, Community Care Licensing Division. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the California Department of Social Services, Community Care Licensing Division.