

GREAT FOUNDATIONS MONTESSORI-NORTHWOOD

4980 IRVINE BLVD.
IRVINE, CA

1 Inspection Visit Since 2024 · 1 Finding

Most recent inspection: Jun 24, 2024

● 1 Important

Across 1 inspection since 2024, the issues cited most often were Based on Record Review, the Licensee Did Not Comply with the Section Cited Above in Lead Sample Report Resulted in Sample Number 220719-LWA-OZ the East Exterior, Spigot, Lead Results Is 17.2 Ppb Which Poses/posed a Potential Health, Safety or Personal Rights Risk to Persons in Care. POC Due Date: 07/24/2024 (1). The single finding was not critical.

Inspection Visits

Jun 24, 2024 1 Finding ● 1 Important

- **Based on Record Review, the Licensee Did Not Comply with the Section Cited Above in Lead Sample Report Resulted in Sample Number 220719-LWA-OZ the East Exterior, Spigot, Lead Results Is 17.2 Ppb Which Poses/posed a Potential Health, Safety or Personal Rights Risk to Persons in Care. POC Due Date: 07/24/2024**

WD 101700(b) Written Directives for Lead Testing (b) All licensed Child Care Centers operating in buildings constructed before January 1, 2010, shall test their water for lead...

About this report

Childery generates this report from public inspection records published by the California Department of Social Services, Community Care Licensing Division. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the California Department of Social Services, Community Care Licensing Division.