

GENENTECH 2ND GENERATION @ ALLERTON

444 ALLERTON AVENUE
SOUTH SAN FRANCISCO, CA

1 Inspection Visit Since 2024 · 1 Finding

Most recent inspection: Nov 15, 2024

● 1 Important

Across 1 inspection since 2024, the issues cited most often were Based on Record Review, the Licensee Did Not Comply with the Section Cited Above by Having Two Fixtures with an Exceedance of Lead Which Poses a Potential Health, Safety or Personal Rights Risk to Persons in Care. POC Due Date: 12/13/2024 (1). The single finding was not critical.

Inspection Visits

Nov 15, 2024 1 Finding ● 1 Important

- **Based on Record Review, the Licensee Did Not Comply with the Section Cited Above by Having Two Fixtures with an Exceedance of Lead Which Poses a Potential Health, Safety or Personal Rights Risk to Persons in Care. POC Due Date: 12/13/2024**

WD 101700.3(b)(2) (2) Licensees shall maintain a lead value at or below the Action Level of 5 ppb in all outlets subject to the testing requirements of these Written Directives,...

About this report

Childery generates this report from public inspection records published by the California Department of Social Services, Community Care Licensing Division. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the California Department of Social Services, Community Care Licensing Division.