

LLESA CHILDREN'S CENTER

1399 ALMOND AVENUE
LIVERMORE, CA

1 Inspection Visit Since 2023 · 1 Finding

Most recent inspection: Aug 22, 2023

1 Important

Across 1 inspection since 2023, the issues cited most often were (Retest Results Provided on 8/22/23). 8 9 10 11 12 13 14 S - Sink Faucet_Pod E Restrooms (Left/right) and P - Sink Faucet_Pod E Oak Room Had a Lead Action Level of Exceedance Response of More Than 5.5ppb. This Poses a Potential Health, Safety and Personal Rights Risk to Children in Care. 8 9 10 11 12 13 14 1 2 3 4 5 6 7 1 2 3 4 5 6 7 1 2 3 4 5 6 7 Failure to Correct the Cited Deficiency(ies), on or Before the Plan of Correction (POC) Due Date, May Result in a Civil Penalty Assessment. (1). The single finding was not critical.

Inspection Visits

Aug 22, 2023 1 Finding 1 Important

- (Retest Results Provided on 8/22/23). 8 9 10 11 12 13 14 S - Sink Faucet_Pod E Restrooms (Left/right) and P - Sink Faucet_Pod E Oak Room Had a Lead Action Level of Exceedance Response of More Than 5.5ppb. This Poses a Potential Health, Safety and Personal Rights Risk to Children in Care. 8 9 10 11 12 13 14 1 2 3 4 5 6 7 1 2 3 4 5 6 7 1 2 3 4 5 6 7 Failure to Correct the Cited Deficiency(ies), on or Before the Plan of Correction (POC) Due Date, May Result in a Civil Penalty Assessment.

CCR 101238(a) 1 2 3 4 5 6 7 101238(a) Buildings and Grounds: The child care center shall be clean, safe, sanitary and in good repair at all times to ensure the safety and...

About this report

Childery generates this report from public inspection records published by the California Department of Social Services, Community Care Licensing Division. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the California Department of Social Services, Community Care Licensing Division.