

PLANZ PRESCHOOL

2400 PLANZ RD
BAKERSFIELD, CA

1 Inspection Visit Since 2025 · 1 Finding

Most recent inspection: Jan 27, 2025

● 1 Important

Across 1 inspection since 2025, the issues cited most often were Based on Record Review and Interview, Kitchen Stove Identified as D, TK1/TK2 Exterior Drinking Fountain Identified as E and F Showed to Have Been Impacted and Results Indicates Out of Compliance Over (ALE) 5.5 Ppb, Which Poses a Potential Health, Safety or Personal Rights Risk to Persons in Care. POC Due Date: 02/27/2025 (1). The single finding was not critical.

Inspection Visits

Jan 27, 2025 1 Finding ● 1 Important

- **Based on Record Review and Interview, Kitchen Stove Identified as D, TK1/TK2 Exterior Drinking Fountain Identified as E and F Showed to Have Been Impacted and Results Indicates Out of Compliance Over (ALE) 5.5 Ppb, Which Poses a Potential Health, Safety or Personal Rights Risk to Persons in Care. POC Due Date: 02/27/2025**

WD 101700(b) Written Directives for Lead Testing (b) All licensed Child Care Centers operating in buildings constructed before January 1, 2010, shall test their water for lead...

About this report

Childery generates this report from public inspection records published by the California Department of Social Services, Community Care Licensing Division. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the California Department of Social Services, Community Care Licensing Division.