

AILEEN COLBURN PRESCHOOL

2201 HELLER AVENUE
ATWATER, CA

1 Inspection Visit Since 2023 · 1 Finding

Most recent inspection: Jan 23, 2023

● 1 Important

Across 1 inspection since 2023, the issues cited most often were During the Indoor Inspection of Classroom #3, LPA Observed the Classroom Did Not Have a Working Carbon Monoxide Detector. Per Staff #3 (S3), the Carbon Monoxide Detector Was Not Working in the Classroom and an Order Had Been Placed Since December 2022; However, the Classroom Had Not Receive a Working Carbon Monoxide Yet. This Poses a Potential Health, Safety or Personal Rights Risk to Persons in Care. POC Due Date: 02/06/2023 (1). The single finding was not critical.

Inspection Visits

Jan 23, 2023 1 Finding ● 1 Important

- **During the Indoor Inspection of Classroom #3, LPA Observed the Classroom Did Not Have a Working Carbon Monoxide Detector. Per Staff #3 (S3), the Carbon Monoxide Detector Was Not Working in the Classroom and an Order Had Been Placed Since December 2022; However, the Classroom Had Not Receive a Working Carbon Monoxide Yet. This Poses a Potential Health, Safety or Personal Rights Risk to Persons in Care. POC Due Date: 02/06/2023**

HSC 1596.954 Licensure Requirements Every licensed child day care center shall have one or more carbon monoxide detectors in the facility that meet the standards established in...

About this report

Childery generates this report from public inspection records published by the California Department of Social Services, Community Care Licensing Division. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the California Department of Social Services, Community Care Licensing Division.