

BOYS & GIRLS CLUB @ SEAFORD

310 VIRGINIA AVENUE
SEAFORD, DE

1 Inspection Visit Since 2026 - 5 Findings

Most recent inspection: Apr 7, 2026

● 5 Important

Across 1 inspection since 2026, the issues cited most often were Notification to OCCL (1), Air Quality and Windows (1), and Heating and Cooling (1). None of the 5 findings were critical.

Inspection Visits

Apr 7, 2026 5 Findings ● 5 Important

● **Notification to OCCL**

14T

Ensure notification to the Office of Child Care Licensing (OCCL) is completed within five days of a resignation, termination, transfer, or hiring of a

● **Air Quality and Windows**

46T

Ensure windows that are used for ventilation have screens. Room 2A had two windows open with no screens.

● **Heating and Cooling**

48T

Ensure heating, air, and ventilation vents in the walls and ceilings are cleaned of dust. All the classrooms and bathroom vents need to be cleaned.

● **Indoor Space**

49T

Ensure that walls, ceilings, and flat surfaces are clean and in good repair. Ensure storage spaces are locked, or chemicals are not accessible if unl

● **Changes Affecting a License**

9T

Ensure that changes that affect the license are approved with the submission of the plan review. The game room and snack room areas have changed, wit

About this report

Childery generates this report from public inspection records published by the Delaware Office of Child Care Licensing. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Delaware Office of Child Care Licensing.