

Bradford County School District - Starke Elementary Pre - K

1000 W Weldon St
Starke, FL

1 Inspection Visit Since 2026 · 1 Finding

Most recent inspection: Mar 18, 2026

● 1 Important

Across 1 inspection since 2026, the issues cited most often were The Facility Did Not Have Documentation of a Fire Extinguisher Being Properly Maintained to Include Being Serviced and Retagged Timely, And/or with a Current Certificate. CCF Handbook, Section 3.8.2, B (Section 2.1 Health and Safety, Page 3) Physical Environment [SR]

Licensing Specialist Observed the Fire Extinguisher Was Tagged on 07/2024. Technical Assistance: B. Fire Extinguishers with a Minimum Rating of 2A:10BC Must Be Properly Installed, Serviced and Maintained with Current Inspection Tags at All Times. Due Date 3/30/2026 FOOD AND NUTRITION (1). The single finding was not critical.

Inspection Visits

Mar 18, 2026 1 Finding ● 1 Important

- **The Facility Did Not Have Documentation of a Fire Extinguisher Being Properly Maintained to Include Being Serviced and Retagged Timely, And/or with a Current Certificate. CCF Handbook, Section 3.8.2, B (Section 2.1 Health and Safety, Page 3) Physical Environment [SR]**

Licensing Specialist Observed the Fire Extinguisher Was Tagged on 07/2024. Technical Assistance: B. Fire Extinguishers with a Minimum Rating of 2A:10BC Must Be Properly Installed, Serviced and Maintained with Current Inspection Tags at All Times. Due Date 3/30/2026 FOOD AND NUTRITION

23-05 - Fire Drills & Emergency Preparedness CCF Handbook, Section 3.8 CCF Handbook, Section 3.8

About this report

Childery generates this report from public inspection records published by the Florida Department of Children and Families, Office of Child Care Regulation. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Florida Department of Children and Families, Office of Child Care Regulation.