

Handley Carly N

1020 Walt Banks Road
Peachtree City, GA

1 Inspection Visit Since 2025 · 1 Finding

Most recent inspection: Nov 6, 2025

● 1 Important

Across 1 inspection since 2025, the issues cited most often were No Hazards Observed Accessible to Children on This Date. Finding 290-2-3-.11(2)(h) Requires at Least One UL Approved Smoke Detector to Be on Each Floor of the Home and Such Detectors to Be Maintained in Working Order. At Least One 2-A:10-B:C Fire Extinguisher Shall Be Kept in the Child Care Area to Be Located No More Than Thirty Feet From the Kitchen. The Extinguisher Shall Be Maintained in Workin (1). The single finding was not critical.

Inspection Visits

Nov 6, 2025 1 Finding ● 1 Important

- **No Hazards Observed Accessible to Children on This Date. Finding 290-2-3-.11(2)(h) Requires at Least One UL Approved Smoke Detector to Be on Each Floor of the Home and Such Detectors to Be Maintained in Working Order. At Least One 2-A:10-B:C Fire Extinguisher Shall Be Kept in the Child Care Area to Be Located No More Than Thirty Feet From the Kitchen. The Extinguisher Shall Be Maintained in Workin**
290-2-3-.11

About this report

Childery generates this report from public inspection records published by the Georgia Department of Early Care and Learning, Child Care Services. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Georgia Department of Early Care and Learning, Child Care Services.