



11/09/2022

Memes Place
3801 Cornell ST
Des Moines, IA 50313

Dear Child Care Provider:

This letter is in regards to the compliance visit at your Registered Child Development Home A conducted on 11/09/2022. Iowa Code Chapter 237A and 441 Iowa Administrative Code, Chapter 110, describes specific requirements that must be met by a Registered Child Development Home. Your home is rated a 1 on the voluntary Quality Rating and Improvement System. The following areas were out of compliance at the time of the visit:

441 IAC 110.8(1) Facility Requirements

441 IAC 110.8(1)“ b” Electrical wiring shall be maintained, and all accessible electrical outlets shall be tamper-resistant outlets or shall be safely capped. Electrical cords shall be properly used. Improper use includes running cords under rugs, over hooks, through door openings, or other use that has been known to be hazardous

441 IAC 110.8(1)“ h” The home shall have at least one single-station, battery-operated, UL-approved smoke detector in each child-occupied room and at the top of every stairway. Each smoke detector shall be installed according to manufacturer’s recommendations. The provider shall test each smoke detector monthly and keep a record of testing for inspection purposes

441 IAC 110.8(4) Emergency Plans

441 IAC 110.8(4) “a” Fire and tornado drills shall be practiced monthly and the provider shall keep documentation evidencing compliance with monthly practice on file for the current year and the previous year.

Findings:

Per the compliance visit conducted by this worker on 11/9/2022 the following corrections described in the above policy sections need to be completed:

1. All electrical outlets are safely capped when not in use. This needs to be done immediately.
2. Smoke detectors need to be tested each month and the tests documented on paper.
3. Fire and tornado drills need to be conducted each month and the testing needs to be documented.

Suggestions/Recommendations:

I recommend you work with your Child Care Resource and Referral Worker (Traci Honold 515-802-8163) to make the above corrections and any other compliance or training efforts.



Iowa Department of Health And Human Services

Kim Reynolds
Governor

Adam Gregg
Lt. Governor

Kelly K. Garcia
Director

Corrective Action Required:

The above corrections need to be completed by 1/9/2023 unless otherwise noted. These corrections will be checked on your next compliance visit.

Non-compliance with any of the mandated requirements listed above may lead to the cancellation or revocation of your Child Development Home Registration. Please take whatever steps are necessary to completely address each of the violations noted above. It is essential you correct all above-mentioned violations.

Please do not hesitate to contact me at DHS at 515-601-9469/jaringd@dhs.state.ia.us if you have any questions regarding this letter.

Sincerely,

Jake Aringdale

Social Worker II

Sheila Aunspach

Social Work Supervisor

Always Remember:

Child Care Resource and Referral is an excellent resource for providers to access training options and support in your area. You can reach Child Care Resource and Referral at 877-216-8481

As you plan your future trainings to meet your 24 hours of training requirement, please remember that you can access the approved training by going to http://www.dhs.state.ia.us/Consumers/Child_Care/Professional_Development.html

You may also access training at: <https://ccmis.dhs.state.ia.us/trainingregistry/>

All providers need to maintain compliance with rules set out in Iowa Administrative Code, Chapter 110, which includes: 441 IAC 110.5(1): Check with the appropriate authorities to determine how the following local, state, or federal laws apply to you: • Zoning code • Building code • Fire code • Business license • State and federal income tax • Unemployment insurance • Worker's Compensation • Minimum wage and hour requirements • OSHA • Americans with Disabilities Act (ADA).