

Daycare Ministry

1200 West U.S. 52
Rushville, IN

1 Inspection Visit Since 2024 · 5 Findings

Most recent inspection: Feb 9, 2024



● 5 Important

Across 1 inspection since 2024, the issues cited most often were One Ccracked Floor Tile Near Door and One Cracked Floor Tile Along Wall in Gym Girls Bathroom Unsanitary. (3) and Ceiling Cracking and Has a Hole in It Near the Decorative Wall in the Sleep Room. (2). None of the 5 findings were critical.

Inspection Visits

Feb 9, 2024 5 Findings ● 5 Important

- **Ceiling Cracking and Has a Hole in It Near the Decorative Wall in the Sleep Room.**
All interior surfaces, equipment, materials, furnishings, and objects with which
- **Items Labeled "KEEP OUT OF REACH OF CHILDREN" or Unsafe Accessible: -Gym Girls Bathroom: Disinfectant Spray, Raid Bug Killer and A & D Ointment in White Cabinet Near Bathroom Door**
All interior surfaces, equipment, materials, furnishings, and objects with which
- **One Ccracked Floor Tile Near Door and One Cracked Floor Tile Along Wall in Gym Girls Bathroom Unsanitary.**
All restrooms shall be equipped with flush toilets and handwashing sinks and sha
- **Papertowels Sitting on Top of White Cabinet Near the Door in Gym Girls Bathroom Unsanitary.**
All restrooms shall be equipped with flush toilets and handwashing sinks and sha
- **Water Temperature Not Maintained Between 100 Degree F and 120 Degree F at Children Handwashing Sinks in the Gym Boys and Girls Bathrooms. (Boys 88.7 Degree F; Girls 87.8 Degree F)**
All restrooms shall be equipped with flush toilets and handwashing sinks and sha

About this report

Childery generates this report from public inspection records published by the Indiana Family and Social Services Administration, Office of Early Childhood and Out-of-School Learning. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Indiana Family and Social Services Administration, Office of Early Childhood and Out-of-School Learning.