

Children Inc Maplelawn IN

1 Inspection Visit Since 2026 · 1 Finding

Most recent inspection: Jan 8, 2026

● 1 Important

Across 1 inspection since 2026, the issues cited most often were No ABC Fire Extinguisher in the Kitchen. No Fire Extinguisher on the Second Level. (1). The single finding was not critical.

Inspection Visits

Jan 8, 2026 1 Finding ● 1 Important

● **No ABC Fire Extinguisher in the Kitchen. No Fire Extinguisher on the Second Level.**

Licensee shall provide a two and one-half (2) pound or greater ABC multiple purp

About this report

Childery generates this report from public inspection records published by the Indiana Family and Social Services Administration, Office of Early Childhood and Out-of-School Learning. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Indiana Family and Social Services Administration, Office of Early Childhood and Out-of-School Learning.