

## Salem Head Start Center

6311 Kratzville Rd  
Evansville, IN

### 1 Inspection Visit Since 2023 - 1 Finding

Most recent inspection: Oct 30, 2023

● 1 Important

Across 1 inspection since 2023, the issues cited most often were The Handwashing Sink in the Classroom Has a Temperature of 79.7 Degrees F. (Water Temperatures Should Be Between 100-120 Degrees F.) (1). The single finding was not critical.

### Inspection Visits

**Oct 30, 2023** 1 Finding ● 1 Important

● **The Handwashing Sink in the Classroom Has a Temperature of 79.7 Degrees F. (Water Temperatures Should Be Between 100-120 Degrees F.)**

Water Supply and Plumbing

#### About this report

Childery generates this report from public inspection records published by the Indiana Family and Social Services Administration, Office of Early Childhood and Out-of-School Learning. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Indiana Family and Social Services Administration, Office of Early Childhood and Out-of-School Learning.