

Little Sprouts Creative Academy

IN

3 Inspection Visits Since 2024 · 5 Findings

Most recent inspection: Jun 20, 2025

● 5 Important

Across 3 inspections since 2024, the issues cited most often were One Staff Member Without a Physical. *Please Send Me Documentation (1), Two Shelving Units Are Unstable and Children Are Climbing on Them, Posing a Hazard to Their Safety. (1), and Several Outlets Are Not Covered, Including a Power Strip in the Kitchen Area and Outlet Near a Crib. (1). None of the 5 findings were critical.

Inspection Visits

Jun 20, 2025

1 Finding

● 1 Important

- One Staff Member Without a Physical. *Please Send Me Documentation
- Direct child care providers who work in the home more than three (3) times a mon

Apr 29, 2024

3 Findings

● 3 Important

- Several Outlets Are Not Covered, Including a Power Strip in the Kitchen Area and Outlet Near a Crib.
- Direct child care providers shall keep protective coverings over exposed electri
- Smoke Detector in Main Child Care Area Has Been Removed and Not Replaced.
- Licensee shall provide electrical or battery-operated smoke detector that is ins
- Two Shelving Units Are Unstable and Children Are Climbing on Them, Posing a Hazard to Their Safety.
- The licensee shall ensure that no conditions exist in the home or on the grounds

Jan 18, 2024

1 Finding

● 1 Important

- Fire Extinguishers Need Replaced in Kitchen and Main Room
- Licensee shall provide a two and one-half (2) pound or greater ABC multiple purp

About this report

Childery generates this report from public inspection records published by the Indiana Family and Social Services Administration, Office of Early Childhood and Out-of-School Learning. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Indiana Family and Social Services Administration, Office of Early Childhood and Out-of-School Learning.