

ript>



Child Care Licensing Program Online Facility Compliance Search

Data last updated 6/1/2026

Child Care Licensing Program Online Facility Compliance Search

Facility Name: Caitlyns Daycare

Survey Reason: Initial Survey

**License
Number:** 00

Date of Survey: 03

K.A.R. 28-4-115 Facility. (c) (11) (A) Has each stairway equipped with balusters not more than four inches apart or guarded to prevent a child's head or body from falling through;
Description : Balusters on back deck are more than four inches apart. Stairs and ramp on the back porch not guarded to prevent a child from falling off the side.

