

ript>



Child Care Licensing Program Online Facility Compliance Search

Data last updated 6/3/2026

Child Care Licensing Program Online Facility Compliance Search

Facility Name: Primrose

License Number: 00

Survey Reason: To investigate a complaint

Date of Survey: 03

Based on the results of the investigation the allegations are substantiated and no additional areas of noncompliance were found. INVESTIGATION COMPLETE.

K.A.R. 28-4-423 Physical plant. (b) (5) Cold water and hot water not exceeding 110° F. shall be supplied to lavatory fixtures accessible to children.

Description : At the time of the survey, one handwashing sink did not have hot water available. Five of seven staff interviewed report that they do not have warm water available for handwashing.

