

Jenkins Head Start

571 Dairy Hollow
Jenkins, KY

3 Inspection Visits Since 2024 · 6 Findings

Most recent inspection: Apr 7, 2026

● 6 Important

Across 3 inspections since 2024, the issues cited most often were 922 KAR 2:120. Section 4. Premises Requirements. (9) Floors, Walls, and Ceilings Shall Be Smooth, in Good Repair, and Constructed to Be Easily cleaned.

Findings:

General: Based on Observation, the Surveyor Found Several Brown Circular Spots on the Ceiling Tiles in Classroom B; Therefore, the Child-care Center Has Failed to Keep the Ceiling In

good Repair. (1), 922 KAR 2:120. Section 12. Toilet, Diapering, and Toiletry Requirements.

(3) A Sink Shall Be:

(a) Located in or Immediately Adjacent to Toilet Rooms;

(b) Equipped with Hot and Cold Running Water That Allows for Hand Washing;

(c) Equipped with Hot Water at a Minimum Temperature of Ninety (90) Degrees Fahrenheit and a Maximum of 120 Degrees Fahrenheit;

(d) Equipped with Liquid Soap;

(e) Equipped with Hand-drying Blower or Single Use Disposable Hand Drying Material;

(f) Equipped with an Easily Clea (1), and 922 KAR 2:090. Section 15. Statement of Deficiency and Corrective Action Plans.

(2) Except for a Violation Posing an Immediate Threat as Handled in Accordance with KRS 199.896(5)(c), a Child-care Center Shall Submit a Written corrective Action Plan to the Cabinet or Its Designee Within Fifteen (15) Calendar Days of the Date of the Statement of Deficiency to Eliminate Or correct the Regulatory violation.

Findings:

A PLAN OF CORRECTION WAS DUE ON 03/13/2025 AND AS OF 08/20/2025, THE PLAN OF CORREC (1). None of the 6 findings were critical.

Inspection Visits

Apr 7, 2026 2 Findings ● 2 Important

About this report

Childery generates this report from public inspection records published by the Kentucky Cabinet for Health and Family Services, Division of Child Care. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Kentucky Cabinet for Health and Family Services, Division of Child Care.

- **922 KAR 2:120. Section 4. Premises Requirements.**
(9) Floors, Walls, and Ceilings Shall Be Smooth, in Good Repair, and Constructed to Be Easily cleaned.
Findings:
General: Based on Observation, the Surveyor Found Several Brown Circular Spots on the Ceiling Tiles in Classroom B; Therefore, the Child-care Center Has Failed to Keep the Ceiling In good Repair.
625 - Floors, Walls, Ceilings

- **922 KAR 2:120. Section 12. Toilet, Diapering, and Toiletry Requirements.**
(3) A Sink Shall Be:
(a) Located in or Immediately Adjacent to Toilet Rooms;
(b) Equipped with Hot and Cold Running Water That Allows for Hand Washing;
(c) Equipped with Hot Water at a Minimum Temperature of Ninety (90) Degrees Fahrenheit and a Maximum of 120 Degrees Fahrenheit;
(d) Equipped with Liquid Soap;
(e) Equipped with Hand-drying Blower or Single Use Disposable Hand Drying Material;
(f) Equipped with an Easily Clea
690 - Sink

Jan 20, 2025 2 Findings ● 2 Important

- **922 KAR 2:090. Section 15. Statement of Deficiency and Corrective Action Plans.**
(2) Except for a Violation Posing an Immediate Threat as Handled in Accordance with KRS 199.896(5)(c), a Child-care Center Shall Submit a Written corrective Action Plan to the Cabinet or Its Designee Within Fifteen (15) Calendar Days of the Date of the Statement of Deficiency to Eliminate Or correct the Regulatory violation.
Findings:
A PLAN OF CORRECTION WAS DUE ON 03/13/2025 AND AS OF 08/20/2025, THE PLAN OF CORREC
195 - Plan of Correction/15 days

- **922 KAR 2:090. Section 8. General.**
(1) A Licensee Shall:
(a) Be Responsible for the Operation of the Child-care Center Pursuant to This Administrative Regula- tion, 922 KAR 2:120, and 922 KAR 2:280; And
(b) Protect and Assure the Health, Safety, and Comfort of Each child.
Findings:
General: Based on Interview, a Three-year-old Child Got His Finger Smashed in the Door Jamb of the Classroom Door. Staff Interviewed Stated That as a Teacher Was Closing The classroom Door the Child Stuck His Fingers In
225 - Licensee Responsibility

Mar 11, 2024 2 Findings ● 2 Important

About this report

Childery generates this report from public inspection records published by the Kentucky Cabinet for Health and Family Services, Division of Child Care. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Kentucky Cabinet for Health and Family Services, Division of Child Care.

● **922 KAR 2:090. Section 11. Staff Requirements.**

(1) Child-care Center Staff:

(b) Shall Provide, Prior to Employment and Every Two (2) Years thereafter:

- 1. A Statement From a Health Professional That the Individual Is Free of Active Tuberculosis; or**
- 2. A Copy of Negative Tuberculin results.**

Findings:

General: Based on Review of Documentation of the Staff Member's Personnel File, the Surveyor Discovered the following:

- 1. A Staff Member's (DOH: 11/24/2021) Personnel File Contained a Negative Tubercu**

405 - TB Verification

● **922 KAR 2:120. Section 4. Premises Requirements.**

(1) The Premises Shall Be:

- (a) Suitable for the Purpose Intended;**
- (b) Kept Clean and in Good repair;**

Findings:

General: Based on Observation, the Surveyor Discovered the following:

Headstart A:

- 1. There Was Dirt Debris on the Navy Rug; Therefore, the Rug Was Not Kept clean.**
- 2. There Were What Appeared to Be Dead Bugs in the Light covers.**
- 3. There Were Pieces of Paper Towels on the Floor Located by the Trash can.**

Headstart B:

- 1. There Was Dirt Debr**

585 - Premises Requirements

About this report

Childery generates this report from public inspection records published by the Kentucky Cabinet for Health and Family Services, Division of Child Care. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Kentucky Cabinet for Health and Family Services, Division of Child Care.