

Covenant Preschool

909 Jefferson Street
Lagrange, KY

3 Inspection Visits Since 2023 · 5 Findings

Most recent inspection: May 7, 2025

● 5 Important

Across 3 inspections since 2023, the issues cited most often were 922 KAR 2:120. Section 4. Premises Requirements. (9) Floors, Walls, and Ceilings Shall Be Smooth, in Good Repair, and Constructed to Be Easily cleaned.

Findings:

General: Based on Observation, Multiple Ceiling Tiles Near the Window in the PreK Classroom Were Stained with Brown Spots, Indicative of Water Damage. (1), 922 KAR 2:120. Section 12. Toilet, Diapering, and Toiletry Requirements.

(3) A Sink Shall Be:

(a) Located in or Immediately Adjacent to Toilet Rooms;

(b) Equipped with Hot and Cold Running Water That Allows for Hand Washing;

(c) Equipped with Hot Water at a Minimum Temperature of Ninety (90) Degrees Fahrenheit and a Maximum of 120 Degrees Fahrenheit;

(d) Equipped with Liquid Soap;

(e) Equipped with Hand-drying Blower or Single Use Disposable Hand Drying Material;

(f) Equipped with an Easily Clea (1), and 922 KAR 2:120. Section 13. Toys and Furnishings.

(2) Indoor and Outdoor Equipment Shall:

(a) Be Clean, Safe, and in Good Repair;

(b) Meet the Physical, Developmental Needs, and Interests of Children of Different Age Groups;

(c) Be Free From Sharp Points or Corners, Splinters, Protruding Nails or Bolts, Loose or Rusty Parts, Hazardous Small Parts, Lead-based Paint,

poisonous Material, and Flaking or Chalking Paint; And

(d) Be Designed to Guard Against Entrapment or Situations That May Cause Stran (1). None of the 5 findings were critical.

Inspection Visits

May 7, 2025 2 Findings ● 2 Important

About this report

Childery generates this report from public inspection records published by the Kentucky Cabinet for Health and Family Services, Division of Child Care. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Kentucky Cabinet for Health and Family Services, Division of Child Care.

- **922 KAR 2:120. Section 4. Premises Requirements.**
(9) Floors, Walls, and Ceilings Shall Be Smooth, in Good Repair, and Constructed to Be Easily cleaned.
Findings:

General: Based on Observation, Multiple Ceiling Tiles Near the Window in the PreK Classroom Were Stained with Brown Spots, Indicative of Water Damage.

625 - Floors, Walls, Ceilings

- **922 KAR 2:120. Section 12. Toilet, Diapering, and Toiletry Requirements.**
(3) A Sink Shall Be:
(a) Located in or Immediately Adjacent to Toilet Rooms;
(b) Equipped with Hot and Cold Running Water That Allows for Hand Washing;
(c) Equipped with Hot Water at a Minimum Temperature of Ninety (90) Degrees Fahrenheit and a Maximum of 120 Degrees Fahrenheit;
(d) Equipped with Liquid Soap;
(e) Equipped with Hand-drying Blower or Single Use Disposable Hand Drying Material;
(f) Equipped with an Easily Clea

690 - Sink

Oct 14, 2024 1 Finding ● 1 Important

- **922 KAR 2:120. Section 13. Toys and Furnishings.**
(2) Indoor and Outdoor Equipment Shall:
(a) Be Clean, Safe, and in Good Repair;
(b) Meet the Physical, Developmental Needs, and Interests of Children of Different Age Groups;
(c) Be Free From Sharp Points or Corners, Splinters, Protruding Nails or Bolts, Loose or Rusty Parts, Hazardous Small Parts, Lead-based Paint, poisonous Material, and Flaking or Chalking Paint; And
(d) Be Designed to Guard Against Entrapment or Situations That May Cause Stran

865 - Indoor/Outdoor Equipment

Sep 14, 2023 2 Findings ● 2 Important

- **922 KAR 2:090. Section 9. Records.**
(1) A Child-care Center Shall Maintain:
(b) A Written Record for Each child:
1. Completed and Signed by the Child's parent;
2. Retained on File on the First Day the Child Attends the Child-care Center; and
3. To Contain:
a. Identifying Information About the Child, Which Includes, at a Minimum, the Child's Name, Address, and Date of Birth;
b. Contact Information to Enable a Person in Charge to Contact the Child's:
(i) Parent at the Parent's Home or Place of Empl

1250 - Enrollment Information

About this report

Childery generates this report from public inspection records published by the Kentucky Cabinet for Health and Family Services, Division of Child Care. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Kentucky Cabinet for Health and Family Services, Division of Child Care.

● **922 KAR 2:090. Section 11. Staff Requirements.**

(1) Child-care Center Staff:

(a) Hired After January 1, 2009, Who Have Supervisory Power Over a Minor and Are Not Enrolled in Secondary Education, Shall Have a:

- 1. High School diploma;**
- 2. GED or Qualifying Documentation From a Comparable Educational Entity; or**
- 3. Commonwealth Child Care Credential as Described in 922 KAR 2:250;**

Findings:

General: Based on Interview and Review of Documentation, a File of a Staff Member Hired on 08/09/2023 Failed to C

400 - Educational Requirements

About this report

Childery generates this report from public inspection records published by the Kentucky Cabinet for Health and Family Services, Division of Child Care. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Kentucky Cabinet for Health and Family Services, Division of Child Care.