

Tina Zibragos

Brightwood Rd
Olney, MD

1 Inspection Visit Since 2024 · 1 Finding

Most recent inspection: Jul 31, 2025

● 1 Important

Across 1 inspection since 2024, the issues cited most often were Licensing Specialist Observed That the Temperature of the Hot Water Exceeded 120 Degrees, It Was Measured at 130 Degrees. (1). The single finding was not critical.

Inspection Visits

Jul 15, 2024 1 Finding ● 1 Important

- **Licensing Specialist Observed That the Temperature of the Hot Water Exceeded 120 Degrees, It Was Measured at 130 Degrees.**

13A.15.05.01E

About this report

Childery generates this report from public inspection records published by the Maryland State Department of Education, Office of Child Care. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Maryland State Department of Education, Office of Child Care.