

# STIMS Little Learners Daycare

Clyde Avenue  
Halethorpe, MD

## 1 Inspection Visit Since 2024 · 1 Finding

Most recent inspection: Jun 23, 2025

● 1 Important

Across 1 inspection since 2024, the issues cited most often were LS Observed the Hot Water Temperature at 130. Provider States She Will Turn Down the Hot Water Tank. Provider Is to Send Proof of Correction to OCC ASAP. (1). The single finding was not critical.

## Inspection Visits

**Mar 14, 2024** 1 Finding ● 1 Important

● **LS Observed the Hot Water Temperature at 130. Provider States She Will Turn Down the Hot Water Tank. Provider Is to Send Proof of Correction to OCC ASAP.**

13A.15.05.01E

### About this report

Childery generates this report from public inspection records published by the Maryland State Department of Education, Office of Child Care. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Maryland State Department of Education, Office of Child Care.