

Gan Toras Emes, LLC.

Cherokee Drive
Baltimore, MD

1 Inspection Visit Since 2026 - 2 Findings

Most recent inspection: Mar 17, 2026

● 2 Important

Across 1 inspection since 2026, the issues cited most often were The Provider Has All Six Emergency Forms. Two Need Updated Information One Needs an Authorized Pick-up and One Needs Pediatrician's Address. The Provider Will Have the Families Add the Information and Will Send the LS a Statement of Correction. (1) and LS Observed That the Hot Water Exceeded 120 Degrees. LS Temperature Reading Was 132.6 F. The Provider Adjust the Hot Water and It Corrected This Non-compliance on Site. the Temp. Went Down to 116 Degrees. (1). None of the 2 findings were critical.

Inspection Visits

Mar 17, 2026 2 Findings ● 2 Important

● **The Provider Has All Six Emergency Forms. Two Need Updated Information One Needs an Authorized Pick-up and One Needs Pediatrician's Address. The Provider Will Have the Families Add the Information and Will Send the LS a Statement of Correction.**

13A.15.03.04A(3)

● **LS Observed That the Hot Water Exceeded 120 Degrees. LS Temperature Reading Was 132.6 F. The Provider Adjust the Hot Water and It Corrected This Non-compliance on Site. the Temp. Went Down to 116 Degrees.**

13A.15.05.01E

About this report

Childery generates this report from public inspection records published by the Maryland State Department of Education, Office of Child Care. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Maryland State Department of Education, Office of Child Care.