

KIRKWOOD UNITED METHODIST PRESCHOOL

201 W ADAMS AVE
KIRKWOOD, MO

1 Inspection Visit Since 2023 - 2 Findings

Most recent inspection: Oct 10, 2023

● 2 Important

Across 1 inspection since 2023, the issues cited most often were Requirements for the Outdoor Play Area Were Not Met as Evidenced by the Fence Had Openings That Were Greater Than 3 1/2 Inches and Allow Entrapment - the Openings Measured 3.5 Inches and 4 Inches. (2). None of the 2 findings were critical.

Inspection Visits

Oct 10, 2023 2 Findings ● 2 Important

- **Requirements for the Outdoor Play Area Were Not Met as Evidenced by the Fence Had Openings That Were Greater Than 3 1/2 Inches and Allow Entrapment - the Openings Measured 3.5 Inches and 4 Inches.**
5 CSR 25-300.090 Physical Plant, Space, Supplies and Equipment 4 (A)
- **Requirements for the Outdoor Play Area Were Not Met as Evidenced by the Fence Had Openings That Were Greater Than 3 1/2 Inches and Allow Entrapment - the Openings Measured 3.5 Inches and 4 Inches.**
5 CSR 25-300.090 Physical Plant, Space, Supplies and Equipment 4 (A)

About this report

Childery generates this report from public inspection records published by the Missouri Department of Elementary and Secondary Education, Office of Childhood. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Missouri Department of Elementary and Secondary Education, Office of Childhood.