

Mundo Magico Day Care

138 Elliot Ave
Yonkers, NY

1 Inspection Visit Since 2026 - 3 Findings - 0% Corrected at Visit

Most recent inspection: Mar 18, 2026

● 3 Important

Across 1 inspection since 2026, the issues cited most often were In Addition to a Smoke Detector on Each Floor, There Must Be a Smoke Detector Located Either Within Rooms Where Children Nap, or in Adjoining Rooms. In the Case (1), Operating Carbon Monoxide Detectors Must Be Used in All Group Family Day Care Homes When Required, and Located in Areas of the Home in Accordance with Applicabl (1), and Each Applicant Must Complete the Office-approved Training That Complies with the Federal Minimum Health and Safety Pre-service Training Requirements or Three-mo (1). None of the 3 findings were critical.

Inspection Visits

Mar 18, 2026 3 Findings ● 3 Important

- **Each Applicant Must Complete the Office-approved Training That Complies with the Federal Minimum Health and Safety Pre-service Training Requirements or Three-mo**
416.14(b)(1)
- **In Addition to a Smoke Detector on Each Floor, There Must Be a Smoke Detector Located Either Within Rooms Where Children Nap, or in Adjoining Rooms. In the Case**
416.4(d)
- **Operating Carbon Monoxide Detectors Must Be Used in All Group Family Day Care Homes When Required, and Located in Areas of the Home in Accordance with Applicabl**
416.5(v)

About this report

Childery generates this report from public inspection records published by the New York State Office of Children and Family Services. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the New York State Office of Children and Family Services.