

Shining Garden Day Care

240 Fenway Drive
Syracuse, NY

1 Inspection Visit Since 2025 - 1 Finding - 100% Corrected at Visit

Most recent inspection: Jun 17, 2025



● 1 Important

Across 1 inspection since 2025, the issues cited most often were In Addition to a Smoke Detector on Each Floor, There Must Be a Smoke Detector Located Either Within Rooms Where Children Nap, or in Adjoining Rooms. In the Case (1). The single finding was not critical.

Inspection Visits

Jun 17, 2025 1 Finding ● 1 Important

- **In Addition to a Smoke Detector on Each Floor, There Must Be a Smoke Detector Located Either Within Rooms Where Children Nap, or in Adjoining Rooms. In the Case**
416.4(d)

Corrected at visit

About this report

Childery generates this report from public inspection records published by the New York State Office of Children and Family Services. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the New York State Office of Children and Family Services.