

Amuse U Daycare

316 Brookfield Rd
Ithaca, NY

1 Inspection Visit Since 2025 · 3 Findings · 100% Corrected at Visit

Most recent inspection: Mar 13, 2025

● 3 Important

Across 1 inspection since 2025, the issues cited most often were Suitable Precautions Must Be Taken to Eliminate All Conditions Which May Contribute to or Create a Fire Hazard. (3). None of the 3 findings were critical.

Inspection Visits

Mar 13, 2025 3 Findings ● 3 Important

- **Suitable Precautions Must Be Taken to Eliminate All Conditions Which May Contribute to or Create a Fire Hazard.**

417.4(a)

Corrected at visit

- **In Addition to a Smoke Detector on Each Floor, There Must Be a Smoke Detector Located Either Within Rooms Where Children Nap, or in Adjoining Rooms. In the Case**

417.4(d)

Corrected at visit

- **Trash, Garbage and Combustible Materials Must Not Be Stored in the Furnace Room, or in Rooms or Outdoor Areas Adjacent to the Home That Are Ordinarily Occupied**

417.4(i)

Corrected at visit

About this report

Childery generates this report from public inspection records published by the New York State Office of Children and Family Services. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the New York State Office of Children and Family Services.