

Sunshine Day Care Center

Price, UT

1 Inspection Visit Since 2025 - 5 Findings

Most recent inspection: Apr 11, 2025

● 5 Important

Across 1 inspection since 2025, the issues cited most often were The Provider Was Out of Compliance with R381-100-19(24) by Not Ensuring That There Were No Sharp Edge Hazards on Any Piece of Play Equipment. In the Outdoor Play Area on the Large Piece of Play Equipment with Two Slides and Bridge, There Was a 3 Inch Hole in the Sliding Surface of One of the Plastic (3), The Provider Was Out of Compliance with R381-100-9(7) by Not Not Ensuring That Windows and Glass Doors Within 36 Inches From the Floor Were Made of Safety or Tempered Glass, or Had a Protective Guard. At the Time of the Inspection, the Glass Doors and Surrounding Windows of the Front Vestibule That (1), and The Provider Was Out of Compliance with R381-100-7-(9)(c) by Not Ensuring That All Caregivers Completed the Preservice Training Offered by the Department. At the Time of the Inspection, One Caregiver Had Not Completed the Requisite Training. (1). None of the 5 findings were critical.

Inspection Visits

Apr 11, 2025 5 Findings ● 5 Important

- **The Provider Was Out of Compliance with R381-100-19(12) by Not Ensuring That Stationary Play Equipment Is Not Placed on a Hard Surface. In the Outdoor Play Area, Two Pieces of Stationary Play Equipment Were Placed Over Hard Ground with a Thin Layer of Artificial Grass Underneath.**

R381-100-19(12)

- **The Provider Was Out of Compliance with R381-100-19(13) by Not Ensuring That an Appropriate Type of Protective Cushioning Covered the Use Zone of Each Piece of Stationary Play Equipment. In the Outdoor Area, Two Pieces of Stationary Play Equipment Were Placed Over Hard Ground with a Thin Layer of Ar**

R381-100-19(13)

- **The Provider Was Out of Compliance with R381-100-19(24) by Not Ensuring That There Were No Sharp Edge Hazards on Any Piece of Play Equipment. In the Outdoor Play Area on the Large Piece of Play Equipment with Two Slides and Bridge, There Was a 3 Inch Hole in the Sliding Surface of One of the Plastic**

R381-100-19(24)

About this report

Childery generates this report from public inspection records published by the Utah Department of Health and Human Services, Office of Child Care Licensing. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Utah Department of Health and Human Services, Office of Child Care Licensing.

- **The Provider Was Out of Compliance with R381-100-7-(9)(c) by Not Ensuring That All Caregivers Completed the Preservice Training Offered by the Department. At the Time of the Inspection, One Caregiver Had Not Completed the Requisite Training.**

R381-100-7(9)(a)-(g)

- **The Provider Was Out of Compliance with R381-100-9(7) by Not Not Ensuring That Windows and Glass Doors Within 36 Inches From the Floor Were Made of Safety or Tempered Glass, or Had a Protective Guard. At the Time of the Inspection, the Glass Doors and Surrounding Windows of the Front Vestibule That**

R381-100-9(7)

About this report

Childery generates this report from public inspection records published by the Utah Department of Health and Human Services, Office of Child Care Licensing. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Utah Department of Health and Human Services, Office of Child Care Licensing.