

TRINITY CHRISTIAN PRESCHOOL

1314 E LEXINGTON BLVD
EAU CLAIRE, WI

1 Inspection Visit Since 2025 - 2 Findings

Most recent inspection: Dec 4, 2025

● 2 Important

Across 1 inspection since 2025, the issues cited most often were Toilets & Sinks - Water Temperature (1) and 251.06(10)(h) (1). None of the 2 findings were critical.

Inspection Visits

Dec 4, 2025 2 Findings ● 2 Important

● **Toilets & Sinks - Water Temperature**

251.06(10)(h)

During a monitoring visit, the water temperature of two of the sinks in the classroom measured at 126 degrees Fahrenheit

● **251.06(10)(h)**

Rule Number

Rule Summary

About this report

Childery generates this report from public inspection records published by the Wisconsin Department of Children and Families, Bureau of Early Care Regulation. Childery did not conduct these inspections or produce the original state reports. Childery is an independent directory and is not affiliated with the Wisconsin Department of Children and Families, Bureau of Early Care Regulation.